



Village of Carleton

1230 Monroe St. Carleton, MI 48117

734.654.6255 Fax 734.654.0477

carletonvillage@carletonmi.us

6-4-2018

Village of Carleton Residents

Dear Residents

This letter is to inform you of problems that we are having with the Sewer Plant lift station on Grafton Road.

On 5-23-2018 we experienced problems with pumping to the sewer plant and the lift station experienced critical flow (we were close to having sewage backing up into homes). We called in the pump company and had our pumps checked, all three pumps went bad and were not pumping. We rented an auxiliary pump and are able to maintain at this time.

We are in the process of getting the 20-year-old pumps rebuilt or at the worst have to replace the pumps.

One of the main problems that we are having is with people putting disposable diapers and baby wipes into the sewer system. These are not really disposable flushable items, as they cause major problems for us at the plant, even when things are running well. These items plug up our pumps and grid screens and take a major amount of time to unplug everything, so again we ask you not to flush these items into the sewer.

We would ask for you to dispose of these items in the trash and help up at the plant.

Thank You

Larry Buckingham

President

Village of Carleton

1230 Monroe Street

Carleton, Mi 48117

O 734-654-6255 C 734-363-5146